

# 419EG Drop Tube Extender for 2” Drop Tube for Gauging Applications

## Installation & Maintenance Instructions



Failure to follow any or all of the warnings may render the part nonfunctional and could result in a hazardous product spill, which may result in property damage, environmental contamination, fire, explosion, injury or death.

---

### Installation



#### WARNINGS

- **Fire Hazard**—Death or serious injury could result from spilled liquids.
- Any modification to this product other than stated in these installation instructions will void the product warranty.
- Install in accordance with all applicable local, state, and federal laws.
- For your safety, it is important to follow local, state, federal and/or OSHA rules that apply to working inside, above, or around the storage tank and piping area. Use all personal protective equipment required for working in the specific environment.
- Tanks could be under pressure. Vapors could be expelled from tank vents, piping, valves or fittings while performing installation. Vapors could catch fire or cause an explosion. Avoid sparks, open flame, or hot tools when working on tanks.
- Fill points should be labeled to identify product being transferred, according to all applicable codes.
- In the event of malfunction, contact Morrison Bros. Co. customer service.

### Steps

1. Ensure Extender is being used on Morrison 2” drop tube.
2. Locate Extender Tool (see Figure 1).
3. Make sure the ends of the drop tube sections are cut square.
4. Locate installation template sticker and follow steps 1-8 listed on template (see Figure 2). When applying label ensure both cut ends are butted together inline and square (see Figure 3). The QR code on template includes a supplemental installation video if needed.
5. Before installing in the tank opening, check the drop tubes and connection for any bends or internal blockages. If any are noticed, you may need to replace the drop tubes or remove blockage before proceeding.

---

### Maintenance

This product should be maintained according to local codes.




#### WARNINGS


- **Fire Hazard** – Death or serious injury could result from spilled liquids.
- You must be trained to maintain this product. Stop now if you have not been trained.
- For your safety, it is important to follow local, state, federal and/or OSHA rules that apply to working inside, above, or around the storage tank and piping area. Use all personal protective equipment required for working in the specific environment.
- Tanks could be under pressure. Vapors could be expelled from tank vents, piping, valves or fittings while performing maintenance. Vapors could catch fire or cause an explosion. Avoid sparks, open flame, or hot tools when working on tanks and tank accessories.



**Figure 1**



**Figure 2**



**Figure 3**

**WARRANTY:** If you believe this product has a defect due to material or workmanship, please contact Morrison for a return authorization. All products are thoroughly tested before shipment and meet all applicable performance standards and specifications. Only material found to be defective in manufacture will be replaced or repaired at our discretion. Claims must be made within one year from the date of installation, and Morrison Bros. Co. will not allow claims for labor or consequential damage resulting from purchase, installation or misapplication of the product. The warranty registration information must be provided to the end user.